

Mr. D. J. Hendrickson
Chief, Utility Safety Section
State of Indiana
Public Service Commission
901 State Office Building
Indianapolis, Indiana 46204

Dear Mr. Hendrickson:

Mr. Kurylo has referred your letter of January 14, 1971, concerning 49 CFR, Section 192.11., petroleum gas systems to me for reply.

This section was intended to exempt from Part 192, LP systems with less than 10 customers not in a public place. We consider a church, school or commercial building as a public place, since each is a place where large numbers of people are exposed to any hazard that may be present. Therefore, the regulations do apply.

Sincerely,

JCC
Chief, Regulations Division
Office of Pipeline Safety