



# Safety Effectiveness of Pressure Relief Devices (PRD) for Compressed Gas Transportation

Research and Development Forum

January 17, 2014

Dr. Refaat Shafkey

PHMSA





# Why Research the Effectiveness of PRDs

- PRDs that release flammable gas where there are other cylinders stored can cause a mass casualty or property damage
- A PRD that releases can cause physical injury to personnel standing nearby





# What is a PRD?

A *pressure and/or temperature* activated device used to prevent the pressure from rising above a predetermined maximum to prevent rupture of a normally charged container when subject to a standard fire.





# PRD Requirements in Regulations: 49 CFR §173.301 (f)

A *cylinder filled with a gas must be equipped with one or more pressure relief devices* (prohibited on cylinder with Div. 2.3 or 6.1 material in Hazard Zone A) sized and selected as to type, location and quantity i.a.w. CGA S-1.1 and CGA S-7.

The *pressure relief device must be capable of preventing rupture of the normally filled cylinder* when subjected to a fire test conducted i.a.w. CGA C-14 or in case of acetylene cylinder CGA C-12.






# Valve Combined With PRD

PRD



PRD



# Typical Types of PRDs




Fig. 1 Type CG-1: Rupture Disk Type Pressure-Relief Device




Fig. 2 Type CG-2, 3: Fusible Plug Type Pressure-Relief Devices. Normally limited to use on cyls with SP ≤ 500 psi




Fig. 3 Type CG-4, 5: Combination Rupture Disk/Fusible Plug Type Pressure-Relief Devices




Fig. 4 Type CG-7: Reclose-able Pressure Relief Device. Normally limited to use on cyls with SP ≤ 500 psi





# Some Accidents Involving Cylinders with PRDs

Propane cylinders

Acetylene cylinders





## Propane Cylinder Fire in Central Florida (July 30, 2013)







# Consequences of Florida Propane Cylinder Fire

**Injuries:** 9 employees, 5 critical with no fatalities

**Emergency Responders:** Over 200 to contain the fire

**Evacuation:** Neighborhoods within a mile of the plant

**Property Damage:** 53000 cylinders destroyed. Plant building roof completely blown away with several vehicles damaged.

**Disruption:** Explosions could be heard and visible 7-10 miles away from the plant.





# Acetylene Fire in Dallas, Texas – July 26, 2007



## **Consequences:**

- Three injuries with two serious.
- Flames shooting 100 feet into the air leading to one-mile evacuation zone around the facility.
- Interstates 30 and 35, were closed in all directions. Area bridges had to be checked for damage.
- Plant building and several vehicles completely damaged
- The region's DART commuter rail service had to be suspended





# Propane Fire in Tulsa Oklahoma



**Nine cars, 1,100 cylinders, two tube trailers.** Fire department reported that the flames were coming “from the pressure relief devices”, forming a large flammable cloud. Once the fire had started, the external impingement from one pressure relief device to another is what set everything on fire





# Research Safety Effectiveness of PRDs

- Accidents and/or incidents involving transportation or use of compressed or liquefied gases in the US and Europe and assess the impact of using or not using PRDs on the outcome
- Whether segregation or storage arrangement of cylinders may have favorable or adverse impact on the event
- The impact of using or not using PRDs on the safety of emergency responders in fire situations involving flammable, non-flammable and low toxicity gases
- Whether existing regulatory provisions and exceptions on propane are proper considering that propane in portable gas cylinders has the greatest exposure to the public

