

PI-77-0105

April 14, 1977

Mr. W.L. Walls  
Gas Field Service  
National Fire Protection Association  
470 Atlantic Avenue  
Boston, MA 02210

Dear Mr. Walls:

This responds to your letter of February 22, 1977, regarding your comments that fire exposure of aboveground plastic pipe should be covered in 49 CFR 192.375.

The requirement that the aboveground portion of a plastic service line be protected against "deterioration and external damage" includes protection from fire exposure. Fire is a form of external damage and, therefore, it is not necessary that it be specifically mentioned.

I look forward to seeing you at the next TPSSC meeting on May 10, 1977.

Sincerely,  
SIGNED  
Cesar DeLeon  
Acting Director  
Office of Pipeline  
Safety Operations

National Fire Protection Association  
470 Atlantic Avenue  
Boston, Massachusetts 02210

February 22, 1977

Mr. Cesar DeLeon, Acting Director  
Office of Pipeline Safety Operations  
Department of Transportation  
2100 Second Street, SW  
Washington, DC 20590

Ref.: Plastic Pipelines

Dear Cesar,

Notice 77-1, Docket No. OPSO-42 reminded me of a concern of mine. As it does not relate directly to this Notice, it obviously cannot be considered a response thereto. I really don't know what use can be made of my concern but, at least, my conscience will be soothed.

When plastic pipe was first proposed (perhaps about 10 years ago) there was pretty universal agreement that it should not be permitted aboveground. There were a number of reasons for this, including its lack of resistance to heat from fire.

The National Fuel Gas Code, ANSI Z223.1 - NFPA 54, has maintained its prohibition of aboveground plastic piping since the matter was initially covered in the 1969 edition, While currently undergoing extensive revision, I am unaware of any requests to modify the Code in this respect,

In contrast, however, 49CFR 192 has permitted plastic pipe aboveground for some time. 49CFR 192,375 does require that the aboveground portion of a plastic service line be protected against "deterioration and external damage", The nature of the deteriorating or damaging influences is not addressed,

It would seem to me that fire exposure should be one of these influences. Fires in grass, weeds, leaves, etc. are not uncommon in the vicinity of those risers. I would not be unduly concerned if failure from fire exposure resulted only in leakage aboveground. We should consider also that regulators and meters in the same fire area are also often of limited fire resistance. However, if the design of the casing would permit underground leakage, then I would be concerned substantially.

Has this aspect been considered?

Sincerely,  
W.L. Walls  
Gases Field Service